

REQUEST FOR INFORMATION

RFI No: 1 Date of Request: 10/7/19 Date Response Required: _____

Contractor: Sillman Wright Architects Package No.: _____ CN: _____

Originator: Colorado River Plumbing, Inc.

Reference Document: _____ Attachments: _____

Problem Identification or Question:

Can we tie into the existing 1" water main underground that feeds the 2 existing hose bibs that are on the east side of the Air Handeler's? ILO running a new line from the meter. I believe this hose bib line runs to this meter anyways.

Initiator of Request: Joe Payson Date: 10/7/19

Suggested Resolution:

Suggested Resolution By: Joe Payson Date _____

Resolution:

Yes, it is ok to connect to the 1" water main that feeds the two existing hose bibs in lieu of running a new line from the meter

Marc Stock Sillman Wright Architects

Resolution By Stephanie Slagter Company / Section Vice President of Admin Services Title _____ Date 7/11/19

Reviewed By _____ Project Manager _____ Date _____

Stephanie Slagan

From: Marc Stock <mstock@sillmanwright.com>
Sent: Monday, July 15, 2019 11:57 AM
To: Nathan Houck; Stephanie Slagan; Shad Lee
Subject: RE: PVCC Temp Housing RFI

All,

Yes, I did speak with the civil engineer on Friday. Our response will be:

Yes, it is okay to connect to the 1" water main that feeds the two existing hose bibs in lieu of running a new line from the meter.

Also, the civil is looking into whether or not we can tie into the existing manhole for sewer to avoid a new connection in the alley. That could save some money.

Marc

Marc Stock

SENIOR DESIGNER

SILLMAN WRIGHT ARCHITECTS

mstock@sillmanwright.com

D: 760.738.8363

C: 951.294.7410

31045 TEMECULA PARKWAY | SUITE 204 | TEMECULA, CA 92592

T: 619.294.7515 | F: 619.294.7592 | WWW.SILLMANWRIGHT.COM

This email and any files transmitted with it are confidential and intended solely for the use of the individual or entity to whom they are addressed. If you have received this email in error, please notify the sender immediately by email and delete this email from your system. If you are not the intended recipient, you are notified that disclosing, copying, distributing or taking any action in reliance on the contents of this information is strictly prohibited.

From: Nathan Houck <nhouck@sillmanwright.com>
Sent: Monday, July 15, 2019 11:39 AM
To: Stephanie Slagan <stephanie.slagan@paloverde.edu>; Shad Lee <shad.lee@paloverde.edu>
Cc: Marc Stock <mstock@sillmanwright.com>
Subject: RE: PVCC Temp Housing RFI

Marc,

Any word from the civil engineer on this?

Thanks,

Nathan Houck | Architect

SILLMAN WRIGHT ARCHITECTS

nhouck@sillmanwright.com

D: 619.501.4977